


ESERCIZIO (Lossy transmission lines: power dissipation)

Calculate the power dissipated by the load in the case of

a) lossless transmission line ($\alpha = 0$)

b) lossy transmission line ($\alpha = 30 \text{ dB/km}$)



$$Z_g = 50 \Omega$$

$$Z_0 = 50 \Omega$$

$$f = 300 \text{ MHz}$$

$$l = 100 \text{ m}$$

$$P_d = 1 \text{ W}$$

a) Lossless line ($\alpha = 0$)

Since $Z_0 = Z_g$, the full power available at the generator section (P_d) is transmitted to the line

$$\Gamma_g = 0 \Rightarrow P_{BB}^+ = P_d (1 - |\Gamma_g|^2) = P_d$$

No power is dissipated by the line, so

$$P_{AA}^+ = P_{BB}^+ = P_d$$

At the load section ($Z_L \neq Z_0$) the reflection coefficient is

$$\Gamma_{AA} = \frac{Z_L - Z_0}{Z_L + Z_0} = 0,584 - j0,383 \quad |\Gamma_{AA}| = 0,7$$

Therefore the power dissipated by the load is

$$P_L = P_{\text{ass}} = P_d (1 - |\Gamma_{AA}|^2) = 0,51 \text{ W}$$

b) Lossy case ($\alpha = 30 \text{ dB/km}$)

$$\alpha \left[\frac{\text{Np}}{\text{m}} \right] = \alpha \left[\frac{\text{dB}}{\text{km}} \right] \frac{1}{8686} = 3,454 \cdot 10^{-3} \text{ Np/m}$$

The reflection coefficient at the ~~load~~ generator section

$$\begin{aligned} |M_{BB}| &= |M_{AA}| e^{-2\alpha l} \\ &= 0,7 e^{-2(3,454 \cdot 10^{-3}) \cdot 100} = 0,35 \end{aligned}$$

The total dissipated power (line + load) is

$$P_{\text{diss}} = P_d (1 - |M_{BB}|^2) = 0,8775 \text{ W}$$

To calculate the power dissipated by the load, we need to evaluate the power available at section AA


$$P_{AA}^+ = P_{BB}^+ e^{-2\alpha l} = P_d e^{-2\alpha l} = 0,5 \text{ W}$$

The power dissipated by the load is

$$P_L = P_{AA}^+ (1 - |M_{AA}|^2) = 0,255 \text{ W}$$

EXERCISE (Power dissipation in lossy transmission lines)

Calculate the power provided by the generator and the power dissipated by the load



$$Z_g = 80 \Omega$$

$$Z_0 = 50 \Omega$$

$$\alpha = 60 \text{ dB}/100 \text{ m}$$

$$Z_L = 50 \Omega$$

$$l = 5 \text{ m}$$

$$Z_0 = Z_L$$

$$\alpha \left[\frac{\text{N}}{\text{m}} \right] = \alpha \left[\frac{\text{dB}}{\text{m}} \right] \frac{1}{8,686} = 0,0091 \text{ Np/m}$$

The reflection coefficient at the load section is

$$|\Gamma_g| = \left| \frac{Z_0 - Z_g}{Z_0 + Z_g} \right| = \left| \frac{50 - 80}{50 + 80} \right| = 0,231$$

The power P_{BB} provided by the generator to the line is

$$P_{BB} = P_d (1 - |\Gamma_g|^2) = 0,947 \text{ W}$$


The power dissipated by the load (P_L) is equal to the total power at section A (P_{AA}) because $\Gamma_{AA} = 0$ (the load is matched to the line impedance)

$$P_{AA} = P_{BB} e^{-2\alpha l} = 0,947 e^{-2 \cdot 0,0091 \cdot 5} = 0,437 \text{ W}$$

ESERCIZIO (Power dissipation in lossy lines)

For the transmission line shown in the figure calculate

- Power dissipated by the load for $d=0$
- Power dissipated by the load for $\alpha = 20 \text{ dB/Km}$
- Power dissipated at the generator section ($\alpha = 20 \text{ dB/Km}$)
- Power dissipated by the line ($\alpha = 20 \text{ dB/Km}$)



$$Z_g \neq Z_0 \neq Z_L$$

$$Z_g = 25 \Omega$$

$$Z_0 = 50 \Omega$$

$$Z_L = 300 \Omega$$

The available power provided by the generator is

$$P_d = \frac{|V_g|^2}{8 \operatorname{Re}[Z_g]} = \frac{100}{8 \cdot 25} = 0,167 \text{ W}$$

a) Lossless case ($\alpha = 0$)

We need to calculate the reflection coefficient Γ_g at the generator section

$$\Gamma_g = \frac{Z_{BB} - Z_g}{Z_{BB} + Z_g}$$

The normalized impedance of the load is

$$\bar{z}_L = \frac{Z_L}{Z_0} = \frac{300}{50} = 6$$

On the Smith Chart we need to rotate \bar{z}_L point by

$$\bar{l} = \frac{l}{\lambda} = \frac{100 \text{ m}}{3 \text{ m}} = \left(33 + \frac{1}{3}\right) \lambda$$

\downarrow
 $\leftarrow \frac{1}{3} \lambda$ effective rotation

After this rotation, we stop at point

$$\bar{z}_{BB} = 0,22 + j0,55$$

that corresponds to $Z_{BB} = \bar{z}_{BB} Z_0 = 11 + j27,5 \text{ } [\Omega]$

The reflection coefficient at the generator is

$$\Gamma_g = \frac{Z_{BB} - Z_g}{Z_{BB} + Z_g} = -0,5824 + j0,506$$

$$|\Gamma_g| = 0,77$$

$$P_L = P_a (1 - |\Gamma_g|^2) = 0,0675 \text{ W}$$

power absorbed by the load for
 $\alpha = 0$

b) Lossy case ($\alpha \neq 0$)

The Smith Chart can be still used, but the attenuation of the line must be taken into account.

$$M'_{BB} = M_{AA} e^{-2\alpha l} = M_{AA} \underbrace{\left(e^{-2\alpha l} \right)}_{\text{amplitude}} \underbrace{\left(e^{-j\beta l} \right)}_{\text{phase}}$$

2 movements onto the Smith Chart

① \Rightarrow phase $e^{-j\beta l}$ is a rotation with $|M| = \text{constant}$

② \Rightarrow amplitude $e^{-2\alpha l}$ is a movement toward the center of the Smith chart

① The same rotation as in the case ($\alpha = 0$)

$$\Rightarrow \bar{z}'_{BB}$$

$$\textcircled{2} |M'_{BB}| = |M_{AA}| e^{-2\alpha l} = 0,7143 \cdot e^{-2(2,3 \cdot 10^{-3})100} = 0,45$$

$$|M_{AA}| = \frac{Z_L - Z_0}{Z_L + Z_0} = 0,7143$$

$$\alpha \text{ [Np/m]} = \frac{\alpha \text{ [dB/km]}}{8,686} = 2,3 \cdot 10^{-3} \text{ [Np/m]}$$

The point M'_{BB} correspond to a normalized impedance

$$\bar{z}'_{BB} = 0,48 + j0,48$$

that is to

$$Z_{BB}' = \bar{z}_{BB}' Z_0 = 24 + j24 [\Omega]$$

The reflection coefficient at the generator is thus

$$|\Gamma_g| = \left| \frac{Z_{BB}' - Z_g}{Z_{BB}' + Z_g} \right| = 0,55$$

The total power absorbed at the generator section is

$$P_{Ass} = P_d (1 - |\Gamma_g|^2) = 0,1156 \text{ W}$$

The forward propagating power at section B is

$$P_0^+ = \frac{P_{Ass}}{1 - |\Gamma_{BB}'|^2} = \frac{0,1156 \text{ W}}{1 - |0,45|^2} = 0,145 \text{ W}$$



$$P_{Ass} = P_0^+ - P_0^-$$
$$|\Gamma_{BB}'|^2 = \frac{P_0^-}{P_0^+}$$

$$P_{Ass} = P_0^+ - P_0^+ |\Gamma_{BB}'|^2 = P_0^+ (1 - |\Gamma_{BB}'|^2)$$

The forward propagating power at section A is


$$P_A^+ = P_0^+ e^{-2\alpha l} = 0,0915$$

The power absorbed by the load is

$$P_L = P_A^+ (1 - |\Gamma_{AA}|^2) = 0,045 \text{ W}$$

The power dissipated by the line is $P_{diss} = P_{Ass} - P_L = 0,07 \text{ W}$

Smith Chart



RADIALLY SCALED PARAMETERS

TOWARD LOAD →										← TOWARD GENERATOR																													
100	40	30	20	15	10	8	6	5	4	3	2	1	1	1	1	1	1	1	1	2	3	4	5	6	8	10	15	20	30	40	100								
0	1	2	3	4	5	6	7	8	9	10	12	14	16	18	20	30	0	0.1	0.2	0.4	0.6	0.8	1	1.5	2	3	4	5	10	20									
1	0.9	0.8	0.7	0.6	0.5	0.4	0.3	0.2	0.1	0.05	0.01	0.0	0.0	0.0	0.0	0.0	1.1	1.2	1.3	1.4	1.6	1.8	2	3	4	5	6	10	15	20									
1	0.9	0.8	0.7	0.6	0.5	0.4	0.3	0.2	0.1	0.05	0.01	0.0	0.0	0.0	0.0	0.0	0.99	0.95	0.9	0.8	0.7	0.6	0.5	0.4	0.3	0.2	0.1	0	0	0									
0.0	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	CENTER										1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
ORIGIN																																							

ATEN (dB)
 SWR LOSS COEFF
 PFL LOSS (dB)
 SWR PEAK CONST. P
 TRANSM. COEFF. P
 TRANSM. COEFF. E x I